
Model: ADC-x/DIG-x

RS-232 / RS-485 Data Acquisition Digital I/O v2.2 Firmware







SuperLogics 94 Falmouth Road Newton, MA 02465 USA

Phone: (617) 332-3627 Fax: (617) 332-4687 Web: www.SuperLogics.com

ADC/DIG User's Manual

Table of Contents

Introduction	2
I/O Module features Quick Start - using Windows Hyperterminal	3 4
Communications	,
RS-485 and RS-232 Packet Description	6
Commands and Responses	
Command & Response Table	7
Command & Response Examples RS-232 Interface	8
Command & Response Examples RS-485 Interface	9
Analog Control Nibble	10
Module Configuration	
DIP Switch and Jumpers	11
EEPROM Map	12
Modes of Operation	
Polled Mode	13
Timed/Async Mode	13
Continuous Mode	14
PCB Details	
Board Illustration	17
IC Description & LED Operation	17
Te Description & DED Operation	17
Connector Pinouts	
Digital & Analog Pinout	18
Power & Communications Pinout	19
RS-232 Cabling	20
	20
Digtial I/O Technical Info	
Digital I/O Specifications and Control	21
PWM	22
Analog Input Technical Info	
Analog Specifications	23
Voltage References & Charge Pump Resistor	23
Analog Voltage Sampling & Conversion	23
Analog Current Sampling & Conversion	25
	20

ADC/DIG User's Manual


Introduction - Features


Welcome to the wonderful world of SuperLogics I/O modules. We offer two different types of I/O module lines: **ADC-x** and **DIG-x**. Each module is available with two different serial interface types: RS-232 and RS-485.

All modules use exactly the same PCB populated with different ICs dependent on the interface and Analog Input requirements.

I/O Module features:

MPU:	Microchip PIC16C65
EEPROM:	Microchip 25C040
MPU Clock:	7.3728 Mhz
Interface:	RS-485 (multidrop up to 255 nodes) or RS-232 (single ended)
Baud:	9600, 19200*, 57600, 115200 (DIP switch selectable, *=default)
LED:	Bicolor diagnostic LED
Watchdog:	MPU has built-in watchdog timer
POR:	MPU contains timed Power On Reset circuitry
Brownout:	MPU brownout detection ciruictry built-in
Temperature:	0°-70°C (32°-158°F) <i>Extended temperature version available</i>
PCB:	FR4
Power:	7.5Vdc - 30.0Vdc, approx. 50 ma.
Transient:	ZNR surge supression on +V power input
	TransZorb protection on RS-485 data lines





ADC/DIG User's Manual

Quick Start

So, you're in a hurry? Let's see if we can help.

You need the following:

- HyperTerminal program (Windows 95/98 or Windows NT)
- An open COMPORT on your PC
- Power supply (we suggest a +9Vdc wall wart)
- A cable to connect your PC to your I/O Module (See PCB Details section for pinout)
- If you have an RS-485 interface, you need a **485-25E** converter.

Make these DIP switch settings

SW1: OFF SW2: ON RS-232 or OFF RS-485 SW3: ON SW4: OFF

Launch the HyperTerminal program

The HyperTerminal program is found under the **Programs - Accessories** folder. Double click on the **Hypertrm.exe** icon to launch the program.

HyperTerminal program configuration

- 1) Create a new connection named "Integrity"
- 2) Select your Comport (COM2 in the example)
- **3)** Set COM Properties: 19200 baud, 8 data bits, No parity, 1 stop bit, Flow control None

			? ×
	Ste	ep 1]
on for th	ne conne	ction:	
act.	8	8	8
C	IK I	Car	ncel
		on for the conne	

^o hone Number	? ×
🧞 Integrity	Step 2
Enter details for	the phone number that you want to dial:
<u>C</u> ountry code:	United States of America (1)
Ar <u>e</u> a code:	218
Phone number:	
Connect using:	U.S. Robotics 56K FAX INT
	U.S. Robotics 56K FAX INT U.S. Robotics 56K FAX INT PnP Direct to Com 1
	Direct to Com 2

ort Settings	S	tep 3
Bits per second:	19200	•
Data bits: 8		
Parity: No	ne	-
<u>S</u> top bits: 1		•
Elow control: No	ne	•
Advanced	<u>R</u> e:	store Defaults
	Cancel	Apply

ADC/DIG User's Manual

Quick Start

HyperTerminal program configuration cont.

4) Under the <u>File</u> menu, select Properties, click on the Settings tab, and adjust the ASCII Setup settings for "Echo typed characters locally" and "Append line feeds to incoming line ends"

Your First Command

Now that you have a HyperTerminal session running, you can start typing. After your first command, see **Commands and Responses** section for more commands.

RS-232

- Type letter V and the Enter Key
- You should see V22 on the screen

RS485

- Type letters 0100V and the Enter Key
- You should see 0001V22 on the screen

File Edit Yiew Çall Iransfer Help Step 4 Step 4 Integrity Properties ?× Phone Number Settings Function, arrow, and ctrl keys act as Send line ends with line feeds Image: Emulation: Auto detect Terminal Setup Character delay: Image: Determinal Keys Phone Number Settings ASCII Sending Send line ends with line feeds Image: Determinal Keys	🎨 Integrity - HyperTerminal	
Integrity Properties Phone Number Settings Function, arrow, and ctrl keys act as Function, arrow, and ctrl keys act as Image: Comparison of the properties ASCII Setup ASCII Setup Image: Comparison of the properties Image: Comparison of the proper		Step 4
Phone Number Settings Function, arrow, and ctrl keys act as Image: Terminal Setup ASCII Setup ASCII Sending ASCII Sending Send line ends with line feeds Image: Setup Auto detect Terminal Setup Ascil Setup Ascil Setup Ascil Sending Image: Setup Send line ends with line feeds Image: Setup I		
Phone Number Settings Function, arrow, and ctrl keys act as Image: Terminal Setup ASCII Setup ASCII Sending ASCII Sending Send line ends with line feeds Image: Setup Auto detect Terminal Setup Ascil Setup Ascil Setup Ascil Sending Image: Setup Send line ends with line feeds Image: Setup I		프
Function, arrow, and ctrl keys act as ASCII Sending Image: Ima	Integrity Properties	
Function, arrow, and ctrl keys act as ASCII Sending Image: Terminal keys Image: Windows keys Image: Terminal Setup Image: Terminal Setup Ascure delay: Image: Terminal Setup	Phone Number Settings	ASCII Setup
Emulation:	Function, arrow, and ctrl keys act as	
Emulation:		Send line ends with line feeds
Auto detect Terminal Setup		Echo typed characters locally
Character delay: 0 milliseconds.		Line delay: 0 milliseconds.
Backsoroll butter lines:	Backscroll buffer lines:	Character delay: 0 milliseconds.
500 -	The second se	
Beep three times when connecting or disconnecting	Beep three times when connecting or disconnecting	
Deep three times when connecting of disconnecting Deep three times times three times times three times times three times ti		
✓ Wrap lines that exceed terminal width		
ASCII Setup OK Cancel	AS <u>C</u> II Setup	OK Cancel
OK Cancel	OK Cancel	
Connected 0:01:47 Auto detect Auto detect SCROLL CAPS NUM Capture Print echo	Connected 0:01:47 Auto detect Auto detect SCR0LL CA	PS NUM Capture Print echo

5


ADC/DIG User's Manual

Communications

The SuperLogics models **ADC-x** and **DIG-x** support both RS-232 and RS-485 communications interfaces. Each interface type uses simple **ASCII** commands. A carriage return (decimal code 13 or Hex code 0x0D) marks the end of a data packet.


RS-232 Interface:

- RS-232 operates Full Duplex
- RS-232 modules can enter Continuous mode whereby the module is configured via EEPROM settings to continuously communicate with the host computer to output its current Digital, Counter or Analog readings.



RS-485 Interface:

- RS-485 operates Half Duplex
- Each module (node) on the bus has a unique Address 1 to 254 (0x01-0xFE hex)
- We use the latest Linear Technologies RS-485 bus drivers (LTC1487) allowing up to **255 nodes** on the RS-485 multi-drop bus
- Address 0 (0x00 hex) is reserved for the Host controller
- Address 255 (0xFF hex) is reserved for Broadcast messages accepted by all modules on the RS-485 bus.



ADC/DIG User's Manual

Firmware v2.2 Command/Response

Command and Response

The following table illustrates the SuperLogics I/O module commands and responses.

<u>NOTE</u>

* All numeric data is represent as ASCII Hexadecimal integers (value x/y in the table)

* If a module receives an illegal or improperly formatted command, Error Response is sent.

* All ASCII characters are CASE SENSITIVE (use all capital letters!)

Command Sent by Host	ResponseDescriptionSent by I/O Module		
V	Vxy	Firmware version x.y	
Ι	Іххуу	Input digital port status xx = PORT1 (PORTB) yy = PORT2 (PORTD) <i>Also returns current output port status</i>	
Оххуу	0	Output digital port: xx = PORT1 (PORTB) yy = PORT2 (PORTD)	
Тххуу	Т	Set digital direction: xx = PORT1 (PORTB) yy = PORT2 (PORTD) bit set(1) = Input, bit clear(0) = Output	
G	Gxxyy	Get current digital direction: xx = PORT1 (PORTB) yy = PORT2 (PORTD) bit set(1) = Input, bit clear(0) = Output	
N	Nxxxx	Get Pulse Counter (xxxx 16 bit counter value)	
М	М	Clear Pulse Counter	
Qy	Qyxxx	Bipolar sample analog (y control nibble , xxx analog value)	
Uy	Uyxxx	Unipolar sample analog (y control niblle, xxx analog value)	
К	Kxx	Get receive error count (xx current count)	
J	J	Clear receive error count	
Рххууу	Р	PWM (xx = PWM frequency, yyy = PWM duty)	
Wyyxx	W	Write EEPROM (yy address, xx value)	
Ryy	Rxx	Read EEPROM (yy address in command, xx value in reponse)	
S	S	Start stream continuous mode	
Н	Н	Halt stream continuous mode	
Z	Z	Reset CPU	
	X	Command error response	

ADC/DIG User's Manual

Command/Response RS-232 Interface

RS-232 Interface Example Commands

The following table illustrates actual command and response data for an RS-232 interface.

<u>NOTE</u>

* All numeric data is represent as ASCII Hexadecimal integers

* The symbol , equates to a carriage return (decimal 13, hex 0x0D)

Command Sent by Host	Response Sent by I/O Module	Description	
V	V20₊J	Module Firmware version 2.0	
I⊷	IFF00₊J	Input digital port [PORT1 bits0-7 ON] [PORT2 bits0-7 OFF] Note: this command also returns the current digital output	
O007F₊J	0	Output digital port [PORT1 bits 0-7 OFF] [PORT2 bit 7 OFF, bits 0-6 ON]	
TFF80₊J	T₊J	Set digital direction [PORT1 bits 0-7 INPUT] [PORT2 bit 7 INPUT, bits 0-6 OUTPUT]	
G₊J	GFF80₊J	Get current digital direction [PORT1 bits 0-7 INPUT] [PORT2 bit 7 INPUT, bits 0-6 OUTPUT]	
N₊J	N0003₊J	Get pulse counter: Current count = 3	
M₊J	M₊J	Clear pusle counter: Current count = 0	
Q1,J	Q100F₊J	Bipolar analog control nibble = $0x1$ Analog reading = $0x00F$	
U8₊J	U840F↓	Unipolar analog control nibble = 0x8 Analog reading = 0x40F	
K₊J	K00₊J	Current receive errors = 0	
JĻ	JĻ	Clear receive error count: Current receive errors = 0	
P08004₊J	P₊J	PWM freq = 51200 Hz, PWM duty = 12.5%	
W0410₊J	W	Write EEPROM Address 0x04 with value 0x10	
R04₊J	R10₊J	Read EEPROM Adress 0x04 (value is 0x10)	
S₊J	S니 IFF00니 Q100F니 IFF00니 Q100F니 	START stream continuous mode See Modes of Operation section This example illustrates stream mode configured to continuously update with Input Digital Port command and Query Analog command with control 0x1. The module continues until a command H↓ is received.	
HĻ	H⊷	HALT stream continuous mode	
Z	Z	Reset CPU (forces a watchdog timeout)	

ADC/DIG User's Manual

Command/Response RS-485 Interface

RS-485 Interface Example Commands

The following table illustrates actual command and response data for an RS-485 interface.

<u>NOTE</u>

- * All numeric data is represent as ASCII Hexadecimal integers
- * Example Host Address = 0x00 and Module Address = 0x13
- * The symbol , equates to a carriage return (decimal 13, hex 0x0D)

Command Sent by Host	Response Sent by I/O Module	Description	
1300V₊J	0013V20₊J	Module Firmware version 2.0	
1300I	0013IFF00₊J	Input digital port [PORT1 bits0-7 ON] [PORT2 bits0-7 OFF] Note: this command also returns the current digital output	
1300O007F₊J	00130₊	Output digital port [PORT1 bits 0-7 OFF] [PORT2 bit 7 OFF, bits 0-6 ON]	
1300TFF80₊J	0013T↓	Set digital direction [PORT1 bits 0-7 INPUT] [PORT2 bit 7 INPUT, bits 0-6 OUTPUT]	
1300G₊J	0013GFF80₊J	Get current digital direction [PORT1 bits 0-7 INPUT] [PORT2 bit 7 INPUT, bits 0-6 OUTPUT]	
1300N↓	0013N0003₊J	Get pulse counter: Current count = 3	
1300M₊J	0013M↓	Clear pulse counter: Current count = 0	
1300Q1₊J	0013Q100F₊J	Bipolar analog control nibble = $0x1$ Analog reading = $0x00F$	
1300U8	0013U840F₊J	Unipolar analog control nibble = 0x8 Analog reading = 0x40F	
1300K↓	0013K00₊J	Current receive errors = 0	
1300J↓	0013J₊J	Clear receive error count: Current receive errors $= 0$	
1300P08004₊J	0013P↓	PWM freq = 51200 Hz, PWM duty = 12.5%	
1300W0410₊J	0013W↓	Write EEPROM Address 0x04 with value 0x10	
1300R04₊J	0013R10₊	Read EEPROM Adress 0x04 (value is 0x10)	
1300S↓	0013X↓J	START stream continuous mode Illegal in RS-485 Mode	
1300H₊J	0013X↓	HALT stream continuous mode Illegal in RS-485 Mode	
1300Z₊J	0013Z₊J	Reset CPU (forces a watchdog timeout after Z, response sent to Host)	

NOTE: A command addressed to Module address 0xFF is accepted by all Modules

ADC/DIG User's Manual

Analog Control Nibble

Analog Control Nibble and Example

The **ADC-x** module utilizes the Linear Technologies LTC1296 analog to digital conversion chip. In the process of performing a data sample, the user sends a control nibble to the **ADC-x** module. The **ADC-x** module in turn performs a data conversion using the control nibble and transmitts a response data sample back. The following table lists each of the 16 possible analog configurations.

<u>NOTE</u>

- * All numeric data is represent as ASCII Hexadecimal integers
- * The symbol → equates to a carriage return (decimal 13, hex 0x0D)
- * See **ADC Technical Info** section for sample to volts conversion

Control Nibble Sent by Host	Analog Sample
0	Differential: CH0+ CH1-
1	Differential: CH2+ CH3-
2	Differential: CH4+ CH5-
3	Differential: CH6+ CH7-
4	Differential: CH0- CH1+
5	Differential: CH2- CH3+
6	Differential: CH4- CH5+
7	Differential: CH6- CH7+
8	Single-Ended: CH0
9	Single-Ended: CH2
А	Single-Ended: CH4
В	Single-Ended: CH6
С	Single-Ended: CH1
D	Single-Ended: CH3
Е	Single-Ended: CH5
F	Single-Ended: CH7

Command Sent by Host	Response Sent by I/O Module	Description
لـQ0	Q100F,J	Bipolar (Q) sample differential CH0+ CH1- (Control = 0) Analog sample = 0x00F (decimal 15)
UA₊J		Unipolar (U) sample CH4 (Control = A) Analog sample = 0x123 (decimal 291)

ADC/DIG User's Manual

Module DIP Switch & Jumper Configuration

DIP switch settings:

1	2	3	4	DIP switch position
		OFF	OFF	9600 baud
		ON	OFF	19200 baud
		OFF	ON	57600 baud
		ON	ON	115200 baud
	ON			RS-232 packet No packet addressing
	OFF			RS-485 packet Packet addressing used
ON				RS-485 Fast response
OFF				RS-485 Delayed response* Wait approx. 2 ms. to send response

*NOTE: Use RS-485 delayed response when using the **485-25E** protocol converter.

Jumper settings:

JP1	JP2	JP3	JP4	Jumper
ON	ON			RS-485 active bus termination
OFF	OFF			No RS-485 bus termination
		Not Used		
			Not Used	

ADC/DIG User's Manual

EEPROM Map - Module Configuration

Address	Description
0x00	Module Address (RS-485 address) [factory default = 0x01]
0x01	Timed/Async Destination Address [factory default = 0x00]
0x02	Data Direction Port 1 (PIC16C65 PORTB) Bit set (1) = Input Bit clear (0) = Output [factory default = 0xFF]
0x03	Data Direction Port 2 (PIC16C65 PORTD)Bit set (1) = InputBit clear (0) = Output[factory default = 0xFF]
0x04	Timed/Async Update Configuration0x00= No Timed/Async updates0x01= Change Update on Digital Input or Counter change0x020xFF = Timed Update (Time = Value * 100 milliseconds)[factory default = 0x00]
0x05 0x0E	Reserved
0x0F	Analog offset calibration (2's complement integer offset to be added to analog bipolar sample)
0x10	Continuous Analog configuration count 0x00 = No analog stream readings 0x010x08 = Number of analog queries See Modes of Operation Stream Continuous for locations 0x100x1A
0x11	Analog Query 1 - control byte - analog control nibble
0x12	Analog Query 2 - control byte - analog control nibble
0x13	Analog Query 3 - control byte - analog control nibble
0x14	Analog Query 4 - control byte - analog control nibble
0x15	Analog Query 5 - control byte - analog control nibble
0x16	Analog Query 6 - control byte - analog control nibble
0x17	Analog Query 7 - control byte - analog control nibble
0x18	Analog Query 8 - control byte - analog control nibble
0x19	Continuous Digital Input configuration 0x00 = Digital Input status OFF 0x01 = Digital Input status ON
0x1A	Continuous Pulse Counter configuration 0x00 = Pulse Counter status OFF 0x01 = Pulse Counter status ON
0x1B 0xFF	Available to User

Modes of Operation

<u>General</u>

The SuperLogics RS-232 I/O modules can operate in three communications modes: Polled, Timed/Async, and Continuous. **These modes of operation can be used singularly or together in combination.**

Mode	Interface
Polled	RS-485 and RS-232
Timed/Async	RS-485 and RS-232
Continuous	RS-232

Polled Mode

By far, the Polled Mode is the most common usage of the ADC-x and DIG-x I/O modules. In this mode the Host computer sends a command to the I/O Modules which in turn sends an associated response back to the Host computer.



Timed/Async Mode

Timed/Async Mode refers to the I/O Module sending data **without** the Host sending a command to poll the I/O Module. This can be viewed as the I/O Module sending a Response without the Host first sending a Command. Async mode reduces communications bus traffic.

NOTE: Timed/Async mode is configured using EEPROM location 0x04.

Value at EEPROM Location 0x04	
0x00	Timed/Async Mode disabled
0x01	Change Update Digital Input or Pulse Counter change
0x02-0xFF (decimal 2-255)	Timed Update Time = Value * .1 second Range = .2 second - 25.5 seconds

ADC/DIG User's Manual

Modes of Operation

Timed/Async Mode — Change Update

When EEPROM location 0x04 = 0x01, the ADC/DIG I/O module enters an asynchronous update mode whereby any detected change on the Digital Input port or the Counter Capture port causes the I/O module to transmit data to the host.

Status Change	Data Sent by I/O Module
Digital Input port change	Ixxxx
Counter Capture change	Nxxxx



Timer/Async Mode — Timed Update

When EEPROM location 0x04 = 0x02...0xFF, the ADC/DIG I/O module enters a timed update mode whereby the I/O module will send data to the host after the specified time period has elapsed.

Time Period = Value (EEPROM location 0x04) * .1 second

When using Async Timed Update, the I/O module uses the **Continuous Mode** configuration to determine the data sent to the host.

Continuous Mode

The final mode of operation is Continuous mode. This mode constantly sends or *streams* data to the host until the host halts the mode. Since the I/O module sends data continuously in this mode, only the RS-232 interface can be configured for Continuous mode. (*RS-485 is half duplex and there would be no way to halt the stream of data coming from the I/O module!*) In brief, the I/O Module can send 0 thru 8 analog samples, digital input status, and the counter capture status.

The I/O module uses parameters found in EEPROM locations 0x10 thru 0x1A to configure the continuous mode. Therefore, the EEPROM must be configured before engaging the Continuous mode.

Continuous mode setup steps

- 1 Configure EEPROM locations 0x10 thru 0x1A
- 2 Begin Continuous mode by sending command 'S' to the I/O Module
- 3 Halt Continuous mode by sending command 'H' to the I/O Module

Modes of Operation

Continuous Mode Configuration — EEPROM Locations

All parameters configuring the Stream Continuous mode are strored in EEPROM. See the following table for a description of the locations and the parameters. Use command '**W**' to update EEPROM values.

EEPROM Location	Value	Description
0x10	0x000x08	Analog Configuration 0x00 = No analog samples 0x010x08 = Number of analog samples
0x11	0x0y 0x0y	Bipolar Analog: y = analog control nibble
Sample 1	0x8y 0x8y	Unipolar Analog: y = analog control nibble
0x12	0x0y 0x0y	Bipolar Analog: y = analog control nibble
Sample 2	0x8y 0x8y	Unipolar Analog: y = analog control nibble
0x13	0x0y 0x0y	Bipolar Analog: y = analog control nibble
Sample 3	0x8y 0x8y	Unipolar Analog: y = analog control nibble
0x14	0x0y 0x0y	Bipolar Analog: y = analog control nibble
Sample 4	0x8y 0x8y	Unipolar Analog: y = analog control nibble
0x15	0x0y 0x0y	Bipolar Analog: y = analog control nibble
Sample 5	0x8y 0x8y	Unipolar Analog: y = analog control nibble
0x16	0x0y 0x0y	Bipolar Analog: y = analog control nibble
Sample 6	0x8y 0x8y	Unipolar Analog: y = analog control nibble
0x17	0x0y 0x0y	Bipolar Analog: y = analog control nibble
Sample 7	0x8y 0x8y	Unipolar Analog: y = analog control nibble
0x18	0x0y 0x0y	Bipolar Analog: y = analog control nibble
Sample 8	0x8y 0x8y	Unipolar Analog: y = analog control nibble
0x19	0x00 0x01 0xFF	Digital Input status disabled Digital Input status enabled
0x1A	0x00 0x01 0xFF	Pulse Counter status disabled Pulse Counter status enabled

Continuous Mode Example

In this example, the I/O module EEPROM is configured to take 2 Analog samples and update the Counter status.

EEPROM Location 0x10	0x02	Take 2 Analog samples
EEPROM Location 0x11	0x08	Sample 1 - Bipolar sample CH0
EEPROM Location 0x12	0x89	Sample 2 - Unipolar sample CH2
EEPROM Location 0x1A	0x01	Pulse Counter Status enabled

ADC/DIG User's Manual

Modes of Operation

Stream Mode Example cont.

The following table illustrates the Host Command and I/O Module responses for the stream conttinuous example configuration and usage.

EEPROM Location 0x10	0x02	Take 2 Analog samples
EEPROM Location 0x11	0x08	Sample 1 - Bipolar sample CH0
EEPROM Location 0x12	0x89	Sample 2 - Unipolar sample CH1
EEPROM Location 0x1A	0x01	Counter Status enabled

<u>NOTE</u>

* All numeric data is represent as ASCII Hexadecimal integers

* The symbol → equates to a carriage return (decimal 13, hex 0x0D)


Host Sends	I/O Module Sends
W1002₊J	W
W1108₊	W
W1289₊J	W
W1A01₊J	W
SL	S₊J Continuous mode started
	Q8023₊J
	U9823,J
	N0044,J
	Q8024,J
	U9823,J
	N0044₊J
	repeats continually
H₽	H,J Continuous mode halted

The HOST may send any command during the Continuous mode and it will be accepted and processed by the I/O Module as in normal operation.

NOTE: Engaging the Continuous mode at a high baud rate (115.2K baud) may overwhelm certain Host computer systems due to the high volume of data transmitted on the RS-232 link. The is especially true of slower 386 or 486 based systems running Windows 95 with limited

ADC/DIG User's Manual

PCB Details



IC Description

- U1 PIC16C65 MPU [44 pin PLCC]
- U2* LTC1487 RS-485 driver [8 pin DIP]
- U3* MAX202 RS-232 driver [16 pin DIP]
- U4 25C040 EEPROM [8 pin DIP]
- U5 LTC1296 [20 pin DIP]
- U6 LM4040 Voltage Reference
- U8 LMC555 Timer charge pump [8 pin DIP]
- R18 Charge pump power supply resistor

NOTE*: U2 and U3 are mutually exclusive.

LED Operation

Blinking Green	[1 per Second]	Unit functioning correctly
Blinking Green	[Rapid or Steady]	Unit receiving serial data
Blinking Red	[Rapid or Steady]	Unit transmitting serial data
No LED		Unit is not functioning

<u>Jumpers</u>


JP1-J	P2
JP3-J	P4

Installed Not used RS-485 active termination at unit

17

ADC/DIG User's Manual


Connector Pinout



DB25 Digital I/O Port

DB25 Digital Port pinout

DB25 Pin	Description
1	Port 2 bit 0 (PIC PORTD 0)
2	Port 2 bit 1 (PIC PORTD 1)
3	Port 2 bit 2 (PIC PORTD 2)
4	Port 2 bit 3 (PIC PORTD 3)
5	Port 2 bit 4 (PIC PORTD 4)
6	Port 2 bit 5 (PIC PORTD 5)
7	Port 2 bit 6 (PIC PORTD 6)
8	Port 2 bit 7 (PIC PORTD 7)
9	PWM output
10	N/A
11	+V_Unreg
12	+5Vdc
13	GND
14	Port 1 bit 0 (PIC PORTB 0)
15	Port 1 bit 1 (PIC PORTB 1)
16	Port 1 bit 2 (PIC PORTB 2)
17	Port 1 bit 3 (PIC PORTB 3)
18	Port 1 bit 4 (PIC PORTB 4)
19	Port 1 bit 5 (PIC PORTB 5)
20	Port 1 bit 6 (PIC PORTB 6)
21	Port 1 bit 7 (PIC PORTB 7)
22	Pulse Counter Input
23	-5Vdc
24	+5Vdc
25	GND



Power Supply

7.5-30Vdc approx. 50 ma. (we suggest a 12Vdc 250ma power supply)

NOTE: Voltage supplies > 17Vdc must alter R18 charge pump resistor value.

GND and Shield

The GND and Shield terminals are connected on the ADC-x/DIG-x board and are therefore electrically equivalent.

RS-485 Cabling

RS-485 wiring is quite simple. Connect all node **A** signals together and all node **B** signals together. Simply run a twisted pair wire to all nodes. Please note that some systems may denote signal **A** as T+/R+ and signal **B** as T-/R-.


RS-485 Termination

The two nodes (units) at the extreme ends of the cable must be terminated: JP1 & JP2 installed. Ensure that only two nodes maximum are terminated.

Connector Pinout

RS-232 Cabling

The RS-232 interface uses a "*3 wire*" RS-232 connection. That is to say only three wires are connected between the I/O Module and the Host PC: **TxD**, **RxD** and **SHD**.



RS-232 Hardware Flow Control

Some RS-232 interfaces may require certain control signals to be wired *loopback* in order to support various Hardware Flow control schemes.

If your Host PC or Controller is using **Hardware Flow** control for serial communications, then use the following chart to loopback the control signals.

RTS-CTSDB25: pins 5-4 wired togetherDSR-DTR-CDDB25: pins 20-8-6 wired together

DB9: pins 8-7 wired together **DB9:** pins 6-4-1 wired together

RS-232 Software Flow Control - Xon/Xoff

The SuperLogics ADC-x/DIG-x I/O modules **do not support Xon/Xoff flow control.**

Digital I/O Technical Info

Digital I/O Characteristics

The following chart lists the Digital I/O characteristics and values.

Characteristic	Value
Digital I/O Current	I/O line source & sink 25 ma Total current PORT1 200 ma Total current PORT2 200 ma
Digital I/O Voltage Levels	Input Off (0) = $0V - 0.8V$ Input On (1) = $2.0V - 5.0V$ Output Off (0) = $0.6V$ max. Output On (1) = $4.3V$ min.
Pulse Counter Input	1 Mhz max. input rate 16 bit counter capture Counter increments on high-low transition

Digital Port Configuration Example

Any Digital I/O configuration changes made to the I/O Module using the '**T**' command are stored in EEPROM locations 0x02 and 0x03.

EEPROM Location 0x02	Port 1 I/O Configuration
EEPROM Location 0x03	Port 2 I/O Configuration

When using either the '**T**' command or directly writing to EEPROM using the '**W**' command, a binary 1 at a bit location puts the I/O line into Input mode, while a binary 0 at a bit location puts the I/O line into Output mode.

<u>NOTE</u>

* All numeric data is represent as ASCII Hexadecimal integers

* The symbol → equates to a carriage return (decimal 13, hex 0x0D)

Host Command	Module Response	Action
T0000₊J	T₊J	All I/O lines are configured as Outputs
TFFFF↓	T₊J	All I/O lines are configured as Inputs
TFF00,⊣	T₊	Port 1 bits 0-7 Inputs Port 2 bits 0-7 Outputs
T00FF,J	T₊J	Port 1 bits 0-7 Outputs Port 2 bits 0-7 inputs
T1234₊J	T₊J	Port 1 bits 4,1 Inputs Port 1 bits 7,6,5,3,2,0 Outputs Port 2 bits 4,5,2 Inputs Port 2 bits 7,6,3,1,0 Outputs

ADC/DIG User's Manual

Digital I/O Technical Info

Pulse Width Modulation (PWM)

The ADC-x and DIG-x I/O modules have a configurable PWM output. There are two settings to configure for proper PWM operation: PWM frequency and PWM duty cycle. The current capability of the PWM output is the same as a Digital I/O line (source & sink 25 ma.)

PWM — Command

Pxxyyy xx = Pwm_Divisor yyy = Pwm_Duty (10 bits max.)

Pwm_Divisor = 0x00 ... 0xFF Pwm_Duty = 0x000 ... 0x3FF

Pwm_Duty = 0, PWM output is disabled (output 0)

PWM — Control

Fpwm = Frequency of PWM output in Hz Pwm_Duty_Percentage = PWM duty cycle (output % on for period Fpwm)

Fpwm = 460800 Hz / (Pwm_Divisor + 1) Duty_Resolution = log (1843200/Fpwm) / log (2) Pwm_Duty_Percentage = Pwm_Duty / 2^{Duty_Resolution}

Pwm_Divisor	Fpwm	Duty_Resolution
0xFF (255)	1800 Hz	10 bits*
0xFE (254)	1807 Hz	10 bits
0x08 (8)	51200 Hz	5 bits
0x00 (0)	460800 Hz	2 bits

If (Pwm_Duty > Duty_Resolution), then Pwm_Duty_Percentage = 100%

*Note: Pwm_Divisor 0xFF cannot achieve complete 100% duty cycle. Use Pwm_Divisor 0xFE if 100% duty cycle is required.

Example PWM Commands

* All numeric data is represent as ASCII Hexadecimal integers

* The symbol → equates to a carriage return (decimal 13, hex 0x0D)

Host Command	Module Response	Action
P0000₊J	P₊	PWM off Any duty cycle of 0 disables PWM output
P08004 ₊	P₊	PWM frequency = 51200 Hz PWM duty = 12.5%
PFE3FF↓	P₊	PWM frequency = 1807 Hz PWM duty = 100%
PFE200₊J	P₊	PWM frequency = 1807 Hz PWM duty = 50%

Analog Input Technical Info

Analog Characteristics

Characteristic	Value
A/D Converter	Linear Tech LTC1296BCN ± .5 LSB Linear Tech LTC1296DCN ± 2 LSB
Linearity Error	Models: ADC-1/-2/-5/-6 LTC1296BCN ± 0.012% (± .5 LSB) Models: ADC-3/-4/-7/-8 LTC1296DCN ± 0.018% (± .75 LSB)
Gain Error	Models: ADC-1/-2/-5/-6 ± 0.012% (± .5 LSB) Models: ADC-3/-4/-7/-8 ± 0.39% (± 4 LSB)
Offset Error	Models: ADC-1/-2/-5/-6 ± 0.17% Models: ADC-3/-4/-7/-8 ± 1.17%
Temperature Drift	100 ppm/ºC (max.)
Max Input Voltage	70V over-voltage protected (R17 10K DIP) 15V over-voltage protected (R17 1K DIP)
Bandwidth	> 1500 SPS max. in continuous mode

Voltage References

We utilize two distinct voltage references in the **ADC-x** Module: a 0.1% voltage reference and a 1.0% voltage reference. These voltage references may be changed by the user. We have included Digikey part numbers for easy ordering. (Digikey phone: 1-800-344-4539)

Voltage	Digikey Part Number
5.000V	0.1% LM4040AIZ-5.0-ND
voltage range +5.0Vdc to -5.0Vdc	1.0% LM4040DIZ-5.0-ND
4.096V	0.1% LM4040AIZ-4.1-ND
voltage range +4.1Vdc to -4.1Vdc	1.0% LM4040DIZ-4.1-ND
2.500V	0.1% LM4040AIZ-2.5-ND
voltage range +2.5Vdc to -2.5Vdc	1.0% LM4040DIZ-2.5-ND
1.200V voltage range +1.2Vdc to -1.2Vdc	0.5% LM4041CIZ-1.2-ND

Charge Pump Resistor

The ADC-x module contains a negative voltage supply in the form of a charge pump driven by U8, an LMC555 timer. This charge pump obtains its voltage from the unregulated power supply input. Since the LMC555 is rated only for +15Vdc, we have designed a simple zener diode power supply fed through R18 to regulate the power into the LMC555 to +12Vdc.

If the power supply voltage > 17Vdc, R18 needs to be replaced with a 1.2K resistor.

ADC/DIG User's Manual

Analog Input Technical Info

Charge Pump Resistor cont.

We supply a 1.2K 1/2W resistor with each **ADC-x** module.

Power supply Voltage	R18 Value
7.5Vdc to 17.0Vdc	120 ohm 1/4W (factory default)
17.1Vdc to 30Vdc	1.2K ohm 1/2W (supplied - not installed)

Sampling Analog Voltage Inputs

By far the most common configuration of the **ADC-x** is to sample voltage values. Analog voltage levels are converted to integer digital values using the Linear Technologies LTC1296 A/D (Analog/Digital) chip. The input voltage range is determined by the reference voltage.

There are two analog sample types: Unipolar and Bipolar

Both A/D sampling types result in a 12 bit binary integer value. This binary integer value is converterd to a voltage depending on the sample type.

Unipolar Analog Sampling

Unipolar analog sampling span is from ground (GND) to voltage reference (Vref). **Only positive voltages are sampled in unipolar mode.** The unipolar sample is represented as an unsigned integer as follows:

Unipolar voltages: 0V ... +Vref

The benefit of using Unipolar samples over Bipolar samples is that a 12bit binary value is spread out over less total voltage span (Vref total.)

1bit unipolar = Vref/4096

Bipolar Analog Sampling

Bipolar analog sampling span is from -Vref to +Vref. Both negative and positive voltages are sampled and represented as a signed binary integer (2's complement) as follows:

Bipolar voltages: -Vref ... 0 ... +Vref

The benefit of using Bipolar sampling over Unipolar is obvious, negative voltages! The downfall of using Bipolar sampling is that a 12 bit binary value is spread out over a larger total voltage span (2*Vref total.)

1bit bipolar = Vref/2048

ADC/DIG User's Manual

Analog Input Technical Info

Voltage Conversion

The Analog conversion value obtained from the **ADC-x** module is represented as an integer value (either signed for Bipolar samples or unsigned for Unipolar sample) and is normally converted to a Real or Floating Point number for ultimate usage.

Vref = 5.000, 4.096, 2.500 or 1.200V

Unipolar Conversion, ADC Sample is an unsigned integer value

Volts [unipolar] = ADC_Sample * (Vref/4096)

Bipolar Conversion, If ADC Sample is a signed integer value

If you are fortunate enough to convert the Bipolar ASCII hexadecimal value directly to a signed integer, then conversion from ADC_Sample to volts is very simple.

Volts [bipolar] = ADC_Sample * (Vref/2048) + Offset_Calibration

Bipolar Conversion, If ADC Sample is an unsigned integer value

Most often the ADC_Sample value is represented as an **unsigned integer**, quite common when converting the Bipolar ASCII hexadecimal analog reading using the 'C' language scanf() function. If an unsigned integer is used, we must manually calculate a negative number.

if (ADC_Sample >= 2048) Volts [bipolar] = (ADC_Sample-4097) * (Vref/2048) + Offset_Calibration

if (ADC_Sample <= 2047) Volts [bipolar] = ADC_Sample * (Vref/2048) + Offset_Calibration

Offset Calibration

The Linear Technologies LTC1296 A/D converter used in the ADC-x modules can exhibit an offset phenomenon. This offset phenomenon is unique to each LTC1296 and a calibration of the offset is required to obtain the most accurate analog readings. The offset calibration is used only with Bipolar analog samples.

To obtain the current A/D offset use the following procedure:

- 1 Connect analog CH0 to GND (use a jumper or clip lead)
- **2** Take a Bipolar analog reading
- **3** The negative (opposite sign) of this value is the offset calibration to be added to samples

At the factory an offset calibration is performed and stored in EEPROM location 0x0F as an 8 bit 2's complement number.

Offset_Stored = 8 bit value at EEPROM location 0x0F

if (Offset_Stored >= 128) Offset_Calibration = (Offset_Stored - 256) * (Vref/2048)

if (Offset_Stored <= 127)

ADC/DIG User's Manual

250 ohm

Analog Input Technical Info

Sampling Current (4-20 ma) Inputs

Many devices output a current value instead of a voltage value. The secret to obtaining current readings is a 250 ohm resistor and a 5V voltage reference. Placing a 250 ohm resistor to ground on a 4-20 ma. current input will create a voltage potential of 1V to 5V.

CHx analog input channel <<-

If we remember Ohm's law:

E = I * R

R = 250 ohms I = .004 to .020 amps (4-20 ma.) E = 1.0V to 5.0V

NOTE: We supply several ultra precision 250 ohm 0.1% resistors with each **ADC-x** module.

Obtaining current readings is a three step process:

- 1 Perform analog Unipolar sample (5.000V reference must be used!)
- 2 Convert unipolar sample to volts
- 3 Convert voltage to amps

Current Conversion

The following formula will convert the raw analog sample reading to a current value.

Current = ADC_Sample * (5.000/4096) * 250

Obtaining accurate Analog samples

Please keep the following points in mind when attempting to obtain accurate samples.

- A) Watch out for UPS systems! They create loads of EMI/EMF noise.
- B) Keep the analog signal source as close to the ADC-x module as possible.
- C) Keep transformers far away from the ADC-x module.
- D) Avoid high impedance analog signal sources.
- E) Use good wiring practices, especially in regards to ground connections.
- F) RS-232 interface can generate approx. 2 mv noise.
- G) RS-485 interface offers the best noise immunity.

<u>Warranty</u>

SuperLogics warranties **all** products against defective workmanship and components for a period of one year after purchase. SuperLogics agrees to repair or replace, at its sole discretion, a defective product if returned to SuperLogics with proof of purchase within this period.